



NAIROBI CITY WATER & SEWERAGE COMPANY LTD.

KAMPALA RD, P. O. Box 30656-00100, Nairobi, Kenya

Tel: +254 0703 080 000

Email: info@nairobewater.co.ke

www.nairobewater.co.ke

NCWSC/PO/LOC/04/2021/VOL.III/7175/BKK

14th September, 2021

ALL BIDDERS

To _____

Dear Sir,

RE: ADDENDUM 1 - NCWSC/04/2021 - PROPOSED GATINA RISING MAIN RE-ROUTING WORKS.

Bidders are advised to take note of the below changes in the BOQ:

Tenderers Query	NCWSC Clarification
<ul style="list-style-type: none">Item A223: Item description is given as "Allow Ksh. 400,000.00 for 4no. laptops for Engineer's Staff" but the Unit of measurement is given as "Months" and the Qty as "9".	<ul style="list-style-type: none">The quantity is 4No laptops and the unit is number (nr) and not months.
<ul style="list-style-type: none">Item A420.3: The "Quantity" for this item was not given and the "Rate" was given as "120".	<ul style="list-style-type: none">120m is the quantity and not the rate
<ul style="list-style-type: none">Item K632.1: The size of the Steel Pipe to be used for the River Crossing has not been indicated.	<ul style="list-style-type: none">The steel pipe for the river crossing should be 12" (DN 300) to marry with the 315mm HDPE pipe being laid.
<ul style="list-style-type: none">Item A223.1: % Adjustment for Contractor's costs and profit for items for Item A223	<ul style="list-style-type: none">Remove the 15%. Bidders to fill their preferred rate.
<ul style="list-style-type: none">Item. A420.3: Sourcing of road cutting/micro tunneling permits road authorities, traffic control and actual micro tunneling for pipes ranging 50-315mm outside diameter.	<ul style="list-style-type: none">Swap the 120 to be in the Quantity column and not in the Rate column. Bidders to fill their preferred rate.
<ul style="list-style-type: none">Item. A420.4: % Adjustment for Contractor's costs and profit for items A.420.1 to A420.4	<ul style="list-style-type: none">Correct the description column to read "% Adjustment for Contractor's costs and profit for bill items A.420.1, A420.2 and A420.4"
<ul style="list-style-type: none">Item K632.1: Steel pipe river aerial crossing, including three reinforced concrete piers and their bases, D20 main rebar's, D12 rings, two reinforced concrete anchor blocks, formworks, straps, surrounds, bearings etc. as per drawing and instructions by the Engineer	<ul style="list-style-type: none">Removed the word "Steel" in the description column and replaced with "DN 300, PN 16 mortar lined socket and spigot steel".

Board of Directors:

B.L.Okumu (Chairman), T.Muriuki (Vice-Chair), N.C.C. County Secretary, N.C.C. C.E.C.M. Finance & Economic Planning, N.C.C. C.O. Water, Sanitation & Energy, M.Kuruga, E. Mukuhi, L.M.Kamba, K. Nyamu,

M.A Abdullahi, Eng. N. M. Muguna (Managing Director)

Please note that the closing date has been extended from **Friday 17th September 2021** to **Friday 24th September, 2021 at 12.00 pm.**

A handwritten signature in blue ink, appearing to read 'Benedict Kiema', enclosed within a circular scribble.

Benedict Kiema
For Managing Director