



NAIROBI CITY WATER & SEWERAGE COMPANY LTD.

KAMPALA RD, P. O. Box 30656-00100, Nairobi, Kenya

Tel: +254 703 080 000

Email: info@nairobiwater.co.ke

www.nairobiwater.co.ke



NCWSC/SCD/CONT/02/2024/VOL.III/10401/WM

21st November, 2024

ALL BIDDERS

To _____

Dear Sir,

RE: ADDENDUM NO. 1 - NCWSC/02/2024 - SUPPLY AND DELIVERY OF HDPE, UPVC PIPES & PPR IN LOTS.

Bidders are advised to take note of the below change in the HDPE Pipes technical specification.

INITIAL TECHNICAL SPECIFICATIONS	REVISED TECHNICAL SPECIFICATIONS
The pipes shall have a safe working pressure of 10bars and test pressure of 16 bars.	The pipes shall have a safe working pressure of 12.5 bars and test pressure of 16 bars. The design pressure = Nominal pressure (PN)

The rest of the technical specifications remain unchanged.

The closing date remains **Wednesday, 27th November, 2024 at 12:00 noon.**

Wilfred Maloba
For Managing Director

Board of Directors:

A. Karanja (Chairman), B. Okumu (Vice-Chair), N.C.C. C.E.C.M. Finance & Economic Planning, N.C.C. C.E.C.M. Green Nairobi, R. Hassan, E. Mukuhi, C. Alaro, E. Wamuiya, J. Mukabwa, Eng. N. M. Muguna (Managing Director)